



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

TWW 48 EVI



55 °C

35 °C



**A++**

**A++**



**53 dB**



- dB

■ 42  
■ **42**  
■ 42  
kW

■ 48  
■ **48**  
■ 48  
kW



2015

811/2013

## TWW 48 EVI

## ErP Data

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 188        | 246        |
| $P_{rated}$ [kW]    | 42         | 48         |
| $Q_{HE}$ [kWh/y]    | 21043      | 16058      |
| SCOP [-]            | 4.70       | 6.14       |
| $T_{bivalent}$ [°C] | -7         | -10        |

|                     |            |            |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 164        | 244        |
| $P_{rated}$ [kW]    | 42         | 48         |
| $Q_{HE}$ [kWh/y]    | 28820      | 19438      |
| SCOP [-]            | 4.11       | 6.10       |
| $T_{bivalent}$ [°C] | -7         | -10        |

|                     |            |            |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 244        | 244        |
| $P_{rated}$ [kW]    | 42         | 48         |
| $Q_{HE}$ [kWh/y]    | 10413      | 10385      |
| SCOP [-]            | 6.09       | 6.10       |
| $T_{bivalent}$ [°C] | -          | -          |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |