




TWW 91 EVI		ErP Data	
		55 °C	35 °C
Energy class		A++	A++
η [%]		173	227
P_{rated} [kW]		80	91
Q_{HE} [kWh/y]		43210	32977
SCOP [-]		4.33	5.67
$T_{bivalent}$ [°C]		-7	-10

Energy class		A++	A++
η [%]		152	225
P_{rated} [kW]		80	91
Q_{HE} [kWh/y]		59177	39863
SCOP [-]		3.79	5.62
$T_{bivalent}$ [°C]		-7	-10

Energy class		A++	A++
η [%]		226	226
P_{rated} [kW]		80	91
Q_{HE} [kWh/y]		21380	21326
SCOP [-]		5.64	5.66
$T_{bivalent}$ [°C]		-	-

CONTROLER

+ QAA55/75

class VII

3.5% ↓

- QAA55/75

class III

1.5% ↓