



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

WW 07 Block



55 °C

35 °C



A++

A++



43 dB



- dB

■ 6
■ **6**
■ 6
kW

■ 7
■ **7**
■ 7
kW



2015

811/2013

WW 07 Block

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	177	229
P_{rated} [kW]	6	7
Q_{HE} [kWh/y]	3003	2292
SCOP [-]	4.43	5.72
$T_{bivalent}$ [°C]	-10	-

Energy class	A++	A++
η [%]	160	236
P_{rated} [kW]	6	7
Q_{HE} [kWh/y]	4112	2774
SCOP [-]	4.01	5.90
$T_{bivalent}$ [°C]	-10	-

Energy class	A++	A++
η [%]	219	220
P_{rated} [kW]	6	7
Q_{HE} [kWh/y]	1487	1483
SCOP [-]	5.48	5.49
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓