



ENERG Y IJA
енергия - ενεργεια IE IA

WAMAK

WW 46 EVI



55 °C

35 °C



A++

A++



51 dB



- dB

■ 41
■ **41**
■ 41
kW

■ 46
■ **46**
■ 46
kW



2015

811/2013

WW 46 EVI

ErP Data

	55 °C	35 °C
Energy class	A++	A++
η [%]	179	234
P_{rated} [kW]	41	46
Q_{HE} [kWh/y]	21265	16245
SCOP [-]	4.47	5.84
$T_{bivalent}$ [°C]	-7	-10

Energy class	A++	A++
η [%]	157	232
P_{rated} [kW]	41	46
Q_{HE} [kWh/y]	29112	19648
SCOP [-]	3.92	5.81
$T_{bivalent}$ [°C]	-7	-10

Energy class	A++	A++
η [%]	232	232
P_{rated} [kW]	41	46
Q_{HE} [kWh/y]	10532	10505
SCOP [-]	5.79	5.81
$T_{bivalent}$ [°C]	-	-

CONTROLLER



+ QAA55/75	class VII	3.5% ↓
- QAA55/75	class III	1.5% ↓