



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

AWK 23 EVI



55 °C

35 °C



**A<sup>+</sup>**

**A<sup>++</sup>**



- dB



**70 dB**

■ 23  
■ **26**  
■ 32  
kW

■ 22  
■ **26**  
■ 32  
kW



2015

811/2013

## AWK 23 EVI

## ErP Data

|                     | 55 °C                | 35 °C                 |
|---------------------|----------------------|-----------------------|
| Energy class        | <b>A<sup>+</sup></b> | <b>A<sup>++</sup></b> |
| $\eta$ [%]          | 117                  | 149                   |
| $P_{rated}$ [kW]    | 26                   | 26                    |
| $Q_{HE}$ [kWh/y]    | 15505                | 12175                 |
| SCOP [-]            | 2.93                 | 3.72                  |
| $T_{bivalent}$ [°C] | -7                   | -7                    |

|                     |          |                       |
|---------------------|----------|-----------------------|
| Energy class        | <b>A</b> | <b>A<sup>++</sup></b> |
| $\eta$ [%]          | 93       | 133                   |
| $P_{rated}$ [kW]    | 23       | 22                    |
| $Q_{HE}$ [kWh/y]    | 23302    | 16395                 |
| SCOP [-]            | 2.34     | 3.33                  |
| $T_{bivalent}$ [°C] | -7       | -7                    |

|                     |                       |                       |
|---------------------|-----------------------|-----------------------|
| Energy class        | <b>A<sup>++</sup></b> | <b>A<sup>++</sup></b> |
| $\eta$ [%]          | 177                   | 177                   |
| $P_{rated}$ [kW]    | 32                    | 32                    |
| $Q_{HE}$ [kWh/y]    | 6546                  | 6535                  |
| SCOP [-]            | 4.42                  | 4.43                  |
| $T_{bivalent}$ [°C] | -                     | -                     |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |