



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

AiWa 08 EVI Out



55 °C

35 °C



**A++**

**A++**



- dB



**63** dB

■ 8  
■ **9**  
■ 12  
kW

■ 8  
■ **9**  
■ 12  
kW



2015

811/2013

## AiWa 08 EVI Out

## ErP Data

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 127        | 160        |
| $P_{rated}$ [kW]    | 9          | 9          |
| $Q_{HE}$ [kWh/y]    | 5108       | 4015       |
| SCOP [-]            | 3.18       | 4.01       |
| $T_{bivalent}$ [°C] | -8         | -8         |

|                     |           |            |
|---------------------|-----------|------------|
| Energy class        | <b>A+</b> | <b>A++</b> |
| $\eta$ [%]          | 107       | 146        |
| $P_{rated}$ [kW]    | 8         | 8          |
| $Q_{HE}$ [kWh/y]    | 7415      | 5428       |
| SCOP [-]            | 2.67      | 3.64       |
| $T_{bivalent}$ [°C] | -8        | -8         |

|                     |            |            |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 186        | 187        |
| $P_{rated}$ [kW]    | 12         | 12         |
| $Q_{HE}$ [kWh/y]    | 2156       | 2153       |
| SCOP [-]            | 4.66       | 4.67       |
| $T_{bivalent}$ [°C] | -          | -          |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |