



**ENERG** Y IJA  
енергия - ενεργεια IE IA

**WAMAK**

BW 05 Block



55 °C

35 °C



**A++**

**A++**



**43 dB**



- dB

■ 5  
■ **5**  
■ 5  
kW

■ 5  
■ **5**  
■ 5  
kW



2015

811/2013

## BW 05 Block

## ErP Data

|                     | 55 °C      | 35 °C      |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 128        | 168        |
| $P_{rated}$ [kW]    | 5          | 5          |
| $Q_{HE}$ [kWh/y]    | 2992       | 2236       |
| SCOP [-]            | 3.20       | 4.21       |
| $T_{bivalent}$ [°C] | -          | -          |

|                     |           |            |
|---------------------|-----------|------------|
| Energy class        | <b>A+</b> | <b>A++</b> |
| $\eta$ [%]          | 114       | 175        |
| $P_{rated}$ [kW]    | 5         | 5          |
| $Q_{HE}$ [kWh/y]    | 4145      | 2694       |
| SCOP [-]            | 2.86      | 4.37       |
| $T_{bivalent}$ [°C] | -         | -          |

|                     |            |            |
|---------------------|------------|------------|
| Energy class        | <b>A++</b> | <b>A++</b> |
| $\eta$ [%]          | 162        | 162        |
| $P_{rated}$ [kW]    | 5          | 5          |
| $Q_{HE}$ [kWh/y]    | 1449       | 1446       |
| SCOP [-]            | 4.04       | 4.04       |
| $T_{bivalent}$ [°C] | -          | -          |

CONTROLLER



|            |           |        |
|------------|-----------|--------|
| + QAA55/75 | class VII | 3.5% ↓ |
| - QAA55/75 | class III | 1.5% ↓ |